



CERTIFICATE

OF AUTHORIZATIONS



We, **CHENGDU GREENFAITH NEW ENERGY TECHNOLOGY CO., LTD.**, who is official manufacturer of Lithium ion battery, having headquarter at No. 619, Tomorrow Base, No. 555, Xinyu Road, High-tech Zone, Chengdu, Sichuan, 610041, P.R.China. Do hereby Authorize.

West American Oversea Trade LLC Oddzial w Polsce

As our **official distributor and service partner** in the Territory of Poland for the following products and services:

Product	Brand
LFR51100、 LFR51200 LFW51100、 LFW51200	LVFU

Region: Poland

Effective Date of Appointment: March 1st, 2025

Period of Validity: 12 Months


SIGNATURE

CHENGDU GREENFAITH NEW ENERGY TECHNOLOGY CO., LTD.



Add: No. 619, Tomorrow Base, No. 555, Xinyu Road, High-tech Zone, Chengdu



Website: www.lvfuenergy.com

<p align="center">TEST REPORT EN IEC 62619 Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for secondary lithium cells and batteries, for use in industrial applications</p>		
<p>Report Number: TSZ23120591-P01-R01</p> <p>Date of issue: 2024-01-10</p> <p>Total number of pages: 7 Pages</p>		
<p>Applicant's name: Chengdu Greenfaith New Energy Technology Co., Ltd.</p> <p>Address: Room 4008, Building 3, 88 Jitai 5th Road, High-Tech Zone, Pilot Free Trade Zone, Chengdu, Sichuan, P.R.China</p>		
<p>Test specification:</p> <p>Standard: EN IEC 62619:2022</p>		
<p>General disclaimer:</p> <p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing laboratory.</p>		
<p>Test item description: LiFePO4 Battery(Li-ion)</p> <p>Trade Mark(s): </p> <p>Manufacturer: Sinocat Environmental Technology Co., Ltd. No.88, Gunan Street, High-Tech Zone, Chengdu City, Sichuan, China</p> <p>Model/Type reference: LFR51100</p> <p>Ratings: 51.2V, 100Ah, 5.12kWh</p>		
Testing Laboratory:		Shenzhen Tiansu Calibration and Testing Co., Ltd.
Testing location/ address		No.2, Jinlong Avenue, Longgang District, Shenzhen, Guangdong, China
Tested by (name, function, signature)		Sean Xie /Test engineer
Reviewed by (name, function, signature) ..		Davis Ding /Reviewer
Approved by (name, function, signature) ..		Duan jiangtao /Approved

Summary of testing:	
Tests performed (name of test and test clause): N/A	Testing location: N/A
The product fulfils the requirements of IEC 62619:2022.	

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

	
Product name	LiFePO4 Battery(Li-ion)
Model	LFR51100
IFpP/49/175/134/[16S]M/-10+30/95	
Parameter	Nominal Voltage:51.2Vd.c.
	Rated Capacity: 100Ah
	Rated Energy: 5.12kWh
positive /negative electrode	Red/ black
Recommended Charge	CC/CV 50A of 57.6V, Cutoff current 5.0A
Date of manufacture	20231129
Code	LC231129J100001
注意事项 (WARNING) :	
1. Read manual before installing. 2.Wait at least 5 minutes after power off before proceeding. 3. Must be grounded before operation. 4.disposal of batteries should follow local regulations.	
	
WARNING Risk of electric shock	
<ul style="list-style-type: none"> ■ Read manual before installing ■ Wait at least 5 minutes after power off before proceeding ■ Must be grounded before operation 	

Test item particulars.....:		
Classification of installation and use.....: To be defined in final product		
Supply Connection DC connector		
Recommend charging method declared by the manufacturer Charging the battery with 50A constant current until 57.6V, then constant voltage until charging current reduces to 5.0A		
Possible test case verdicts:		
- test case does not apply to the test object.....: N/A		
- test object does meet the requirement.....: P (Pass)		
- test object does not meet the requirement.....: F (Fail)		
Testing.....:		
Date of receipt of test item N/A		
Date (s) of performance of tests N/A		
General remarks:		
"(See Enclosure #)" refers to additional information appended to the report.		
"(See appended table)" refers to a table appended to the report.		
Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.		
Name and address of factory (ies) Same as manufacturer		
General product information and other remarks:		
The battery of model LFR51100 is composed of sixteen lithium-ion cells (16S1P), and equipped with overcharge, overdischarge, overcurrent, and short circuit protection circuits.		
- Battery (Model: LFR51100) has been evaluated to comply with ST/SG/AC.10/11/Rev.7/Section 38.3, test report No.: TSZ23120118-P02-R01 issued on 2023-12-29, issued by Shenzhen Tiansu Calibration and Testing Co., Ltd.		
	Cell	Battery
Model	48173125-100Ah	LFR51100
Rated capacity(Ah)	100	100
Nominal voltage(V)	3.2	51.2
Recommended Charge Current(A)	50	50
Maximum Charge Current(A)	130	100
Recommended Discharge Current(A)	50	50
Maximum Discharge Current(A)	130	100
Maximum Charge Voltage(V)	3.65	57.6
End-of-discharge Voltage(V)	2.5	43.2
Charge temperature Range(°C)	0~60	0~55
Discharge temperature Range(°C)	-30~60	-18~58
Nominal mass(kg)	approx. 2.25	48±1
External dimensions(mm)	173.9*132.2*48.0	482.0±1*468.0±1*178.0±1

Remark:

- 1) At the request of the customer, add applicants and change their corresponding models and product name, other information remains unchanged.
- 2) Change the applicant's name from " **Chengdu Greenfaith New Energy Technology Co., Ltd.** " to " **Chengdu Greenfaith New Energy Technology Co., Ltd.** ", See Page 1:
- 3) Change model from " **ZT-51100J** " to " **LFR51100** ", See Page 1
- 4) Change product name from " **Rack mounted Li-ion battery** " to " **LiFePO4 Battery(Li-ion)** ", See Page 1

For above change, No related test was considered necessary.

Product Photo




Figure 1 Front view of battery system




Figure 2 Back view of battery system

Amendment sheet:

Revision	Issue Date	Revision Content	Revised By
0	2024-01-10	Original report	Sean Xie
1	2024-01-10	At the request of the customer, add applicants and change their corresponding models and product name, other information remains unchanged. This report is based on the report No. TSZ23120180-P01-R01, there is no need to retest, this report is invalid without the original report	Sean Xie

CERTIFICATE

of Conformity

EC Council Directive 2014/30/EU

Certificate No.: XK2312013090C-A1

Applicant : Chengdu Greenfaith New Energy Technology Co., Ltd.
Room 4008, Building 3, 88 Jitai 5th Road, High-Tech Zone, Pilot
Free Trade Zone, Chengdu, Sichuan, P.R.China

Manufacturer : Sinocat Environmental Technology Co., Ltd.
No.88, Gunan Street, High-Tech Zone, Chengdu City, Sichuan,
China

Product : LiFePO4 Battery(Li-ion)

Model/Type No : LFW51200, LFW51100, LFR51100, LFR51200

Brand Name : N/A

Test Standard : EN IEC 61000-6-3:2021
EN IEC 61000-6-1:2019
EN 61000-3-3:2013+A2:2021+AC:2022
EN IEC 61000-3-2:2019+A1:2021

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report is at the applicant disposal. This is to certify the tested sample that is in conformity with all provisions of above EMC directive. It is only valid in connection with the test report number XK2312013090E-A1.

The certificate does not imply the assessment of the production and does not permit using the SiCT's logo without permission.



Authorized Signer:

Andy Wang

Andy Wang/Manager

Date: January 12, 2023

**Shenzhen SiCT Technology Co., Ltd.**202, Building 3, No.111 Huanguan Middle Road, Songyuanxia Community,
Guanhu Street, Longhua District, Shenzhen, Guangdong, ChinaE-mail: info@sict-lab.com.cn Http:// www.sict-lab.com.cn